

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Flush box-inserted installation switches

Name and address of the applicant
Nom et adresse du demandeur

GOAP d.o.o. Nova Gorica
Ulica Klementa Juga 7
SI-5250 Solkan, Slovenia

Name and address of the manufacturer
Nom et adresse du fabricant

GOAP d.o.o. Nova Gorica
Ulica Klementa Juga 7
SI-5250 Solkan, Slovenia

Name and address of the factory
Nom et adresse de l'usine

See page 2

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2ème page

☒ Additional Information on page 2

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

230 / 240 V~; 50-60 Hz; T40; I_{max} Shutter = 4 A; I_{max} 2 Relays =
2x 4 A; I_{max} 1 Relay = 10 A; I_{max} 1D Relay = 10 A

Trademark (if any)
Marque de fabrique (si elle existe)

Qubino

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

/

Model / Type Ref.
Ref. De type

Flush Shutter; Flush 2 Relays; Flush 1 Relay; Flush 1D Relay

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent
être indiqués sur la 2^{ème} page

☒ Additional Information on page 2

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60669-1:1998 (Third Edition) + A1:1999 + A2:2006
IEC 60669-2-1:2002 (Fourth Edition) + A1:2008

As shown in the Test Report Ref. No. which forms
part of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

T211-0733/15


This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



SIQ Ljubljana
Tržaška cesta 2, SI-1000 Ljubljana, Slovenia
T +386 1 4778 100, F +386 1 4778 444, info@siq.si, www.siq.si
Product Certification Body is accredited by Slovenian Accreditation, Reg. No.: CP-001

Date: 2015-12-15

Signature: Alja Pregl



Type references and technical data:

Flush Shutter (Two-way switch with one off-position)

230 / 240 V~; 50-60 Hz; T40; $I_{\max \text{ Shutter}} = 4 \text{ A}$

Flush 2 Relays (Double-pole switch)

230 / 240 V~; 50-60 Hz; T40; $I_{\max 2 \text{ Relays}} = 2 \times 4 \text{ A}$;

Flush 1 Relay (Single-pole switch)

230 / 240 V~; 50-60 Hz; T40; $I_{\max 1 \text{ Relay}} = 10 \text{ A}$

Flush 1D Relay (Single-pole switch; voltage free contact)

230 / 240 V~; 50-60 Hz; T40; $I_{\max 1D \text{ Relay}} = 10 \text{ A}$

Name and address of the factory:

- 1.) DEC elettronica srl, Via dell'Artigianato 12/1, I-31040 Chiarano (TV), Italy
- 2.) ASTREL S.R.L., Via Isonzo 21/E, I-34070 Mossa (GO), Italy

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2015-12-15

Signature: Alja Pregl

